

TEST REPORT EU FACADE TEST 9

Name of sponsor:	The Danish Institute of Fire and Security Technology		
Product name:	EU-facade test draft 6		
File no.:	PGC10039A	Revision no.:	0
Test date:	2024-09-05	Date:	10-10-2024
Pages:	13	Encl.:	84
Ref:	MMN	/ CHD	

Client information

Client: The Danish Institute of Fire and Security Technology

Address: Jernholmen 12
2650 Hvidovre
Denmark

The results relate only to the items tested. The report should only be reproduced in extenso - in extracts only with a written agreement with this institute.

Content

Client information	2
Content	3
Date of test.....	4
Purpose of test	4
Test specimen.....	4
Drawings and description	5
Description.....	5
Measured by DBI.....	8
Test conditions	8
Conditioning	8
Mounting	8
Test results	10
Measurements.....	10
Visual observations:.....	12
Conclusion	13
Remarks	13

Date of test

The test was conducted on 2024-09-05

Purpose of test

Examination of the fire performance of a façade using the large fire exposure.

The test specimen has been subjected to a fire test in accordance with the following draft standards:

ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE

Draft revision 6

Draft Date: 2022 – 11 – 18

The test was not performed accredited.

Test specimen

The trade name and sponsors identification mark are stated below:

Trade name:	BFUH-9
Identification mark:	None

The components for the test specimen were delivered and mounted by the sponsor.

Drawings and description

Details of the construction are shown in the enclosed documentation as stated below:

Type	Drawing No.	Dated	Subject
Drawing	1	08-14-2024	Facaderamme
Drawing	2	08-14-2024	Vindspærre
Drawing	3	08-14-2024	L Afstandslister
Drawing	4	08-14-2024	V Afstandslister
Drawing	5	08-14-2024	Facadebeklædning
Drawing	DE01-03	08-14-2024	Detaljer
Drawing	samlet	08-14-2024	samlet
Drawing	Indd. 2090	08-13-2024	1 mm plade
Drawing	Indd. 1290	08-13-2024	1 mm plade
Drawing	GKB-122142-50	08-14-2024	2 mm plade
Drawing	GKB-122142-40	08-14-2024	2 mm plade
Drawing	GKB-122142-30	08-14-2024	2 mm plade
Drawing	GKB-122142-20	08-14-2024	2 mm plade
Drawing	GKB-122142-10	08-14-2024	2 mm plade

The documentation is supplied and stamped by DBI - Danish Institute of Fire and Security Technology

Description

The test specimen consisted of the components described in the following. DBI inspected the components during mounting, the test and after the test.

The sponsor carried out the selection of the products for the test specimen as well as the mounting.

Test specimen

External measures: Height: 7600 mm Main width: 3680 mm Wing width: 1500 mm Thickness: 282 mm
With flame deflector: 489 mm

The test specimen was a ventilated façade made of vertical wood cladding, mounted on horizontal formwork. Flame deflector profiles were installed above fire chamber and windows on the main facade. The façade wing consisted of 100 mm thick aerated concrete.

The build-up of the facade system is shown on the attached drawings, supplied by the sponsor. The construction of the facade is described from the first layer on the aerated concrete frame.

First Layer: The first layer consisted of prefabricated cassettes which were built from untreated construction wood C24 with dimensions 45 x 195 mm which had a nominal density of 480 kg/m³. A 45 x 95 mm wooden beam with a nominal density of 480 kg/m³ was mounted on the bottom construction wood. There were 3 cassettes in total, and they were mounted with 289 mm horizontal gap in between. See drawing No. 1.

The backside of the prefabricated cassettes was closed with a 12 mm OSB board.

Fixing of first layer: The construction woods C24 were fixed to each other with steel angles designated Simpson Strong-tie ABR9020 with screws designated Paslode DS413 4.0 x 40 mm at 4 corners of the cassette.

The T- conjunctions of the construction woods were fixed with nails designated TJEP GR 3.1 x 90 mm with a c/c distance of 20 mm.

The OSB boards were fixed on the prefabricated cassette with nail designated Tjep ZE 2.5 x 65 ring. The c/c distance of the nails was approx. 150 mm.

The cassettes were put on 2 ACW 155 Simpson strong-tie console bracket which were fixed to the aerated concrete frame with 4 screws designated Spit ACS CSK ø8 x 90/30 mm. One screw designated Paslode 5.0 x 40 mm was used to connect the cassette and each console bracket. All the other edges of prefabricated cassettes were fixed to the aerated concrete with steel angles designated Paslode 90 x 90 x 65. 4 screws designated Paslode 5.0 x 40 mm were used to connect the angle to the wood. The angles were fixed to the aerated concrete with one screw designated Spit ACS CSK ø8 x 90/30 mm. The angles were mounted with a c/c distance of approx. 600 mm in horizontal and 900 mm in vertical. The gap between the cassettes and the concrete was approx. 15 mm.

Gaps in the first layer: The gaps between the cassettes were filled with insulation. The insulation designated Rockwool flexibatts 37 with the thickness of the wall with the nominal density of 32 kg/m³ were placed in the gap. The gap was closed off by the second layer (weatherboard), mounted on to a 25 x 50 mm wooden batten in the top of the gap. The wood had a nominal density of 450 kg/m³. See drawing No. DE01-03.

The 45 x 45 mm wooden batten with a nominal density of 450 kg/m³ was fixed to the construction wood C24 with screws designated NKT Spun+ 4.5 x 70 mm. See drawing No. DE01-03.

Insulation in the cassette: The insulation in the cassettes consisted of 195 mm Rockwool Flexibatts 37 with a nominal density on 32 kg/m³.

Second layer: The second layer was 9 mm boards designated swisspearl windstopper extreme, which had a nominal density of 1375 kg/m³. See drawing No. 2.

Fixing of second layer: The boards were fixed with nails designated Tjep ZE 2.5 x 50 mm with a c/c distance of 300 mm.

Knauf W tape 60 mm x 22.8 mm was used to close off joints of the board after mounting.

Flame deflector: The flame deflectors were made with 2 mm steel profile. The profile was fixed on the façade with screws designated RedHorse CORONA™ RXB 4.8 X 60 EPDM-9.5B, the c/c distance between screws was 300 mm. Top and bottom profile fasten with RF rivet designated Gesipa 4.0 x 8.0 mm, the c/c distance between rivets was approx. 200 mm. The longitudinal holes were minimum 20 mm long and the screws were placed in the middle of elongated hole during assembly so that expansion could take place. The flame deflectors protruded 200 mm out from the surface of the cladding and protruded approx. 500 mm out from the edge of the main façade. The air gap inside the Flame deflectors was filled with insulation at the ends to prevent a horizontal air flow. Rockwool with a nominal density of 32 m³/kg, was put inside the flame bender at the joints.

All details about the flame deflectors are shown on the following drawings: GKB-122142-50, GKB-122142-40, GKB-122142-30, GKB-122142-20, GKB-122142-10 and drawing samlet.

Formwork: The impregnated wood formworks with a dimension of 22 x 45 mm with a nominal density of 450 kg/m³ were mounted vertically and then horizontally on the main facade. See drawing No. 3 and 4.

- Fixing of formwork: The vertical formwork was nailed with 2.5 x 65 mm Tjep ZE, per 120 mm. The horizontal formwork and wooden batten were nailed with 3.1 x 90 mm Tjep ZE, per 600 mm.
- Cladding: Wooden planks designated Thermowood fer & not with a dimension of 21 x 117 mm and nominal density of 400 kg/m³ with groove and tongue were mounted horizontally on the top of the formworks as the cladding.
- Fixing of cladding: The cladding was fixed on the formwork horizontally with two nails per profile designated Tjep ZE 2.5 x 50 mm ring. See drawing No.5.
- Window and fire chamber details: The powder-coated galvanized steel profiles were mounted around the window and fire chamber with Tjep ZE 2.5 x 50 mm Ring nails. The c/c distance of nails was 300 mm.
- Insulation and sealant: 45 mm soft stone wool was mounted on the cassettes, where the prefabricated cassettes was mounted to the concrete, pressed up against the stone wool.
- The side of the main façade was covered by mineral wool insulation. See photo No. 10.
- Between the prefabricated cassette and the aerated concrete around the fire chamber and the window, the ceramic wool was used to close the gap.
- Fire sealant was used to close off the gaps around the window.

Measured by DBI

Product		195x45 wood (C24)	95x45 wood	*45x25 wood	45x45 wood (C14)	Cladding wood	*Rockwool Flexibatts 37, 45mm	Rockwool Flexibatts 37, 195mm	Swisspearl windstopp er
Density	kg/m ³	488	363	628	562	461	*20	32	1519
Thickness	mm	43,5	44,6	25,7	44,4	25,1	44,5	195	8,8
Moisture content	%	16,3	14,0	57,1	15,6	5,3	0,2	0,2	2,9
Organic content	%	-	-	-	-	-	2,9	2,5	-
Sampling method		Extra material	Extra material	Extra material	Extra material	Extra material	Extra material	Extra material	Extra material
Drying temperature	°C	105	105	105	105	105	105	105	55

*25 x 45 wood had a measured moisture content on 57.1%. The density of the wood had also been measured to be 628 kg/m³, which is an increase on above 30 % from the nominal density.

*The measured density of Rockwool Flexibatts 37, 45mm had been measured to be 20 kg/m³, which is a decrease on above 30 % from the nominal density.

Test conditions

Conditioning

The materials for the test specimen were delivered on the 21-08-2024 to the DBI laboratory and stored under room temperature. On the day of the fire testing the condition of the test specimen was similar with respect to its moisture content as the test specimen would be in normal service.

The installation of the test specimen on the test rig was completed on the 29-08-2024.

Mounting

The test specimen was mounted on the test rig that had a size of 8040 mm in height and with main surface of 3600 mm and wing 2150 mm wide. The surface of the test rig was built with 150 mm aerated concrete blocks, with a nominal density of 575 kg/m³.

The design and location of the combustion chamber opening in the main face was in accordance with the design details specified in the standard ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE Draft revision 6, Draft Date: 2022 – 11 – 18.

Each of the two vertical sides was closed off with stone wool before the fire test

The fire test was conducted in the following conditions:

- Ambient temperature: approx. 24 °C at the start of the test (see Enclosures 3.0 and 3.1)
- Ambient air velocity: Not measured (test undertaken indoor where ambient air speed and/or wind did not affect the test)
- Mechanical exhaust: 80.000 m³/h (at ambient temperature) even distributed in the ceiling of the test hall with a combined exhaust duct to the air filter cleaning system.

Observations were made during the test on the general behaviour of the test specimen.

Temperature observations were taken continually during the entire testing time.

The temperatures were measured on the external and internal layers of the test specimen as indicated on DBI drawing enclosure no. 1.0 - 1.1. All thermocouples that were used according to the standard ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE are named I.1.1-1.9, I.2.1-2.5, I.3.1-3.5. All other thermocouples are for informative uses.

The temperature was determined by means of type-K sheathed thermocouples specified in, ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE.

The thermocouples named I.1.1-1.9, I.2.1-2.5, I.3.1-3.5. were constructed of junctions of nickel chromium/nickel aluminium (type K) wire as defined in EN 60584-1 contained within mineral insulation in a heat resisting alloy sheath of nominal diameter 2.0 mm. Designated as a sheathed thermocouple.

The furnace plate thermocouples were constructed according to EN 1363-1, and all other thermocouples were made from type-k thermocouples wire with 0.5mm in diameter twisted together in the end.

The wood crib was constructed flowing the principles in ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE. The dimensions of the spruce sticks were approx. 45 x 45 mm and the external dimension of the 24-layer wood crib was 1.5m x 1m x 1.08m (width x depth x height). The wood crib was stored at approx. 20°C in dry conditions and was at the time of the fire test in equilibrium with the surroundings. The spruce sticks were nailed together to construct the crib and was installed on a closed bottom surface made of a 20 mm thick calcium silicate board with dimensions of 1300 mm x 1900 mm. The crib was placed 100 mm from the back wall and centred from the sidewalls of the combustion chamber. The average density of the wood was approx. 500 kg/m³.

In front of the combustion chamber, a platform was placed which had a size of 1850 x 3200 mm. It was placed with the upper edge 100 mm below the floor of the combustion chamber. This was done to simulate a comparable air flow and buoyancy that will occur if the weight for fallings parts was used. which should have been placed in front of the facade according to ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE section 4.7.4.

The test was terminated after 61 minutes.

Test results

Duration of the test was 60 minutes.

Measurements

The enclosed graphs and tables show:

Enclosures 2.0 and 2.1 The temperature in the fire chamber during the test

Enclosures 3.0 and 3.1 Ambient temperature
The ambient temperature in the laboratory during the test

Enclosures 4.0 and 4.1 Location 1 - Flux

Enclosures 5.0 and 5.1 Temperature measured in the ventilated cavity

Enclosures 6.0 and 6.1 Temperature measured in the ventilated cavity

Enclosures 7.0 and 7.1 Location 1,2 - Plate TC 1.4m and 2.5m height
Plate TC.1 Location 1
Plate TC.2 Location 2

Enclosures 8.0 and 8.1 Location 2 - 5 m from facade 4.5 m height.

Enclosures 9.0 and 9.1 Location 1 - TC on PlateTC

Enclosures 10.0 and 10.1 Location 1 - TC on Flux
Flux.TC.2 located 3 m from fire chamber

Enclosures 11.0 and 11.1 Location 2 - TC
TC.1 Location 1
TC.2 Location 2

Enclosures 12.0 and 12.1 Temperature rise measured 50mm from the facade

Enclosures 13.0 and 13.1 Temperature rise measured in ventilation layer

Enclosures 14.0 and 14.1 Temperature rise measured in middle of insulation

Enclosures 15.0 and 15.1 Temperature rise measured according to the standard - 50 mm from facade.
Minimum of 30 sec

Enclosures 16.0 and 16.1	Temperature rise measured according to the standard - ventilation layer. Minimum of 30 sec
Enclosures 17.0 and 17.1	Temperature rise measured according to the standard - in the middle of the insulation. Minimum of 30 sec
Enclosures 18.0 and 18.1	Vertical measurements on main facade
Enclosures 19.0 and 19.1	Vertical measurements on main facade
Enclosures 20.0 and 20.1	Vertical measurements on the wing
Enclosures 21.0 and 21.1	Vertical measurements on the wing
Enclosures 22.0 and 22.1	Horizontal measurements
Enclosures 23.0 and 23.1	Horizontal measurements
Enclosures 24.0 and 24.1	Plate thermocouple on facade
Enclosures 25.0 and 25.1	Heat flux on window
Enclosures 26.0 and 26.1	TC on window heat Flux Flux.TC. on window
Enclosures 27.0 and 27.1	Temperature rise measured behind the windbreaker board

Visual observations:

Time / Visual observations:**Minutes**

0	Test commences
0.54	Flames had reached the window
1.51	Top profile in fire chamber began to bend
2.26	Cladding began to burn around the fire chamber
3.34	Flames had reached the top flame bender
4.02	Cladding began to burn in the horizontal direction
4.29	Cladding began to burn on the right side of the window
5.13	Cladding began to burn under the top flame bender.
8.17	Cladding burned heavily around the fire chamber.
11.28	Flames was spread further to the sides.
14.38	The flames where crawling over the top flame bender in the corner of the façade.
16.32	The top flame bender began to deform at the gap in the top of it.
21.32	Flames had spread through most of the cladding.
22.16	Cladding began to fall and burn.
35.50	Most of the cladding had fallen.
38.00	Windbreaker boards started cracking.
50.00	All cladding had fallen, except from the left side of the façade.
50.40	The flames reached past the top flame bender at the top and were touching the cladding.
60.00	Test stopped. No visible charring or burning parts on the top element.

The photographs on the attached photo sheets show the test specimen during the mounting, testing and after the test. See the description at each photo.

Conclusion

Fire testing according to daft version of: ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE, the construction described in this test report showed that failure according to the performance criteria stated in the test method occurred at the following time:

Performance	Criteria	Test result
Fire spread		
	Vertical fire spread	No failure
	Horizontal fire spread	44 minutes
	Burning parts	23 minutes
Falling parts – Level 0		
	Falling parts – (Level 0)	23 minutes
Falling parts – Level 1		
	Falling parts – (Level 1)	Not measured
Falling parts – Level 2		
	Falling parts – (Level 2)	Not measured

The test was terminated after 60 minutes.

Remarks

The test was an Ad-Hoc test, there is no field of application.

This report details the method of construction, the test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in ASSESSMENT OF FIRE PERFORMANCE OF FACADES USING LARGE FIRE EXPOSURE.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

This report has only been printed in a pdf-version. DBI has not issued a hard copy version.
All values mentioned in this report are nominal values, production tolerances are not considered.

The test was not performed accredited.

Danish Institute of Fire and Security Technology



Mads Møllgren
Resistance to Fire Engineer



Chunyang Dong
M.Sc. (Safety Eng.)

The Danish Institute of Fire and Security Technology


Jernholmen 12
2650 Hvidovre
Denmark

Enclosures:

84

DBI drawings:	4
DBI graphs and tables:	52
Photo sheets:	14
Sponsors drawings:	14

BFUH-9



Materialer:

22mm Frøslev klinkeprofil – Termowood (lodret) LBM:
Rundhovedet rustfri A4 pistolsøm 2,5x50

Generelt:

-

Opbygning:

22mm Frøslev klinkeprofil – Termowood (lodret)
22x45mm Afstandslistre (brandimpregnere) pr. 600mm (krydsforskallet)
9mm Swisspearl Windstopper Extreme
45x195mm stoplekonstruktion pr. 600mm
195mm Stenuld (isolering kl 37)
195mm Stenuld (isolering kl 37) (over vinduer og i lukkestykker)

Revisionstekst:

A) Element ændret til version som BFUH 7

● Thermocouple location on the facade surface proposed by Guoxiang (5 cm from the wood panel surface).

○ Thermocouple location on the facade surface required according to the standard (3 measurements: 5 cm out on exposed surface, middle of cavity and center of insulator).
I.1.6 -> I.1.9 50mm ud igennem facade (Hele vejen igennem)
I.2.6 + I.2.8 1 midten af ventilationslag
I.3.6 + I.3.8 1 midten af isolering

○ Thermocouple location on the facade surface required according to the standard (2 measurements: 5 cm out on exposed surface and middle of the cavity).
I.1.1 -> I.1.5 50mm ud igennem facade (Hele vejen igennem)
I.2.1 -> I.2.3 1 midten af ventilationslag
I.3.1 -> I.3.3 1 midten af isolering

▲ Thermocouple within the ventilated cavity.

● Water cooled heat flux censore at the center of the second window.

■ Plate thermometer at the surface of the facade, flush to the surface of the facade.

● Velocity probe locations for flow velocity measurement

File no.:PGC10039A

Test date: 05-09-2024

Enclosure: 1.0

Danish Institute of Fire and security Technology

Subject: EU FAcade test 9

BFUH-9 Facadetest ved DBI - Test 1

Facadebeklædning

BYGHERR:

Fælledby

-

DATO: 2024-08-01

REV. NR/DATO:

Gældende

ANSV: CMA


MÅL: 1:30

ANTAL: -

TEGN.NR:

5

BFUH-9



● Thermocouple location on the facade surface proposed by Guoxiang (5 cm from the wood panel surface).

○ Thermocouple location on the facade surface required according to the standard (3 measurements: 5 cm out on exposed surface, middle of cavity and center of insulator).


○ Thermocouple location on the facade surface required according to the standard (2 measurements: 5 cm out on exposed surface and middle of the cavity)

▲ Thermocouple within the ventilated cavity.

● Water cooled heat flux censor at the center of the secondary window.

■ Plate thermometer at the surface of the facade, flush to the surface of the facade.

File no.: PGC10039A
Test date: 05-09-2024
Enclosure: 1.1
Danish Institute of Fire and security Technology
Subject: EU FAcade test 9



BFUH-9 Facadetest ved DBI - Test 1

V Afstandslistre

BYGHERRER:
Fælledby
-

DATO: 2024-08-01

REV. NR/DATO:

Gældende

ANSV: CMA


MÅL: 1:30

ANTAL: -


TEGN.NR:

4

BFUH-9



File no.:PGC10039A
Test date: 05-09-2024
Enclosure: 1.2
Danish Institute of Fire
and security Technology
Subject: EU FAcade test 9



BFUH-9 Facadetest ved DBI - Test 1

Facaderamme

DATO: 2024-08-01 REV. NR/DATO: A 2024-08-14

BYGHERRE:
Fælledby
-

ANSV: CMA

MÅL: 1:30

ANTAL: -

TEGN.NR:


1

Revisionstekst:

A) Element ændret til version som BFUH 7

BFUH-9

CAMERA LOCATION



NOTE:

- Location 1: 3 m away to the center of the combustion chamber (both horizontally and vertically), a plate thermometer, a thermocouple and a water cooled heat flux censor.
 - Location 2: 5 m away from the facade wall, 2.5 m above the ground and 4.5 m above the ground, a plate thermometer and a thermocouple.
 - Location 3 : 1 camera from the side view, 4 meters hight, mounted on the SP-FIRE rig, observering the test from the side.
 - Location 4: 1 camera from front view, 4 meters hight, mounted on the gas-beton rig, at the opposite end of the facadehall in the corner.
 - Location 5: 6 blue LED lights, light should focus on the second section of the facade.
 - Location 6: two plate thermometers + two wire thermocouples inside the combustion chamber.
 - Location 7 and 8: bi-direction velocity tube together with a wire temperature thermocouple to measure the measuring the flow speed towards the wood crib
- Note: height indicator every 500 mm at two edges of the facade.

File no.:PGC10039A


Test date: 05-09-2024

Enclosure: 1.3

Danish Institute of Fire and security Technology

Subject: EU FAcade test 9

The temperature in the fire chamber during the test



FireChamberPlateTC.1 FireChamberPlateTC.2
FireChamberTC.1 FirechamberTC.2


The temperature in the fire chamber during the test

Min. / °C	FPT.1	FPT.2	FPT.3	FPT.4
0	23	23	23	23
2	23	24	23	23
4	696	720	443	385
6	735	716	612	722
8	815	826	663	707
10	845	868	719	788
12	875	921	766	849
14	904	950	813	886
15	929	968	834	904
16	933	988	851	919
18	964	993	889	937
20	1017	1026	945	970
22	1052	1046	986	994
24	1076	1046	1021	1000
26	1067	930	1025	943
28	926	859	936	897
30	881	812	893	854
32	861	775	862	828
34	779	712	809	786
36	710	645	774	752
38	652	596	734	723
40	618	562	714	692
42	589	528	696	670
44	570	508	680	654
46	552	494	667	641
48	545	474	654	625
50	495	429	618	596
52	478	419	598	580
54	459	401	585	566
56	430	410	567	554
58	419	401	557	546
60	397	403	547	539
61	383	394	542	533

FireChamberPlateTC.1 FireChamberPlateTC.2
 FireChamberTC.1 FirechamberTC.2

Ambient temperature


The ambient temperature in the laboratory during the test



Ambient temperature

The ambient temperature in the laboratory during the test


Min. / °C	Amb.1
0	24
2	24
4	24
6	25
8	26
10	26
12	27
14	28
15	29
16	29
18	30
20	31
22	33
24	33
26	33
28	32
30	32
32	32
34	32
36	31
38	31
40	31
42	31
44	31
46	31
48	31
50	31
52	31
54	31
56	31
58	31
60	30
61	31

Location 1 - Flux

Location 1 - Flux


Min. / kW/m ²	Location 1 - Flux.1
0	0
2	0
4	7
6	11
8	15
10	18
12	22
14	25
15	23
16	24
18	26
20	29
22	31
24	31
26	31
28	28
30	24
32	23
34	21
36	19
38	19
40	17
42	16
44	16
46	14
48	13
50	12
52	12
54	12
56	11
58	11
60	11
61	11

Temperature measured in the ventilated cavity




Temperature measured in the ventilated cavity

Min. / °C	V.1.1	V.1.2	V.1.3	V.1.4	V.1.5	V.1.6	V.1.7	V.1.8
0	23	23	23	23	23	23	24	24
2	23	23	23	23	24	23	24	24
4	24	25	24	24	94	110	44	66
6	26	28	26	27	117	139	40	75
8	27	30	27	29	204	398	42	87
10	29	31	28	30	347	634	43	95
12	31	33	30	33	445	714	49	94
14	33	35	32	36	446	756	53	106
15	34	36	33	37	461	796	53	107
16	35	37	34	39	451	788	54	111
18	37	42	36	44	453	784	55	112
20	40	45	39	49	495	841	59	115
22	43	48	42	52	529	860	56	149
24	45	49	44	54	605	872	57	377
26	47	50	45	54	679	865	63	471
28	46	51	46	53	816	878	85	495
30	46	50	47	55	863	872	129	575
32	46	50	48	54	908	921	367	800
34	45	48	48	53	831	823	713	898
36	45	49	48	56	741	734	632	905
38	45	47	48	53	571	532	651	659
40	45	45	48	51	592	467	687	376
42	44	46	48	52	523	394	703	407
44	44	45	48	53	586	311	721	278
46	44	44	48	52	543	256	708	220
48	43	44	48	50	504	241	711	263
50	43	45	48	50	614	225	748	377
52	43	43	47	50	627	220	751	714
54	43	43	47	49	683	275	806	657
56	42	42	47	48	883	888	631	725
58	42	43	48	47	939	940	738	711
60	42	42	48	46	729	770	633	705
61	41	41	48	46	701	734	606	671

Temperature measured in the ventilated cavity

Temperature measured in the ventilated cavity

Min. / °C	V.1.9	V.1.10	V.1.11	V.1.12	V.1.13	V.1.14
0	23	23	23	23	24	23
2	23	23	23	23	24	23
4	27	30	61	37	145	127
6	27	43	110	39	147	154
8	28	71	295	50	231	141
10	29	106	384	57	350	156
12	35	239	556	69	506	613
14	40	301	597	89	549	640
15	42	287	591	108	547	675
16	43	308	576	117	553	765
18	45	314	613	160	588	717
20	44	301	612	163	678	752
22	42	457	680	303	795	826
24	45	504	715	606	816	807
26	48	555	754	757	791	793
28	52	584	835	833	812	825
30	55	643	824	839	798	768
32	64	718	780	809	801	759
34	82	780	792	848	783	755
36	95	835	807	900	726	682
38	114	854	820	862	693	668
40	135	823	788	843	605	431
42	263	859	841	871	460	321
44	910	885	862	827	495	398
46	789	899	891	851	551	501
48	724	867	869	829	615	570
50	747	890	885	862	703	712
52	787	941	912	914	662	669
54	823	940	947	920	637	653
56	865	897	855	845	670	650
58	876	872	836	816	643	619
60	837	865	862	900	671	631
61	846	816	828	830	679	654


Location 1,2 - Plate TC 1.4m and 2.5m height

Location 1,2 - Plate TC 1.4m and 2.5m height

Plate TC.1 Location 1


Plate TC.2 Location 2

Min. / °C	Plate TC.1	Plate TC.2
0	23	23
2	23	24
4	71	29
6	179	38
8	256	51
10	305	63
12	334	74
14	360	86
15	370	92
16	387	98
18	410	112
20	436	126
22	457	135
24	469	140
26	471	143
28	455	143
30	435	134
32	420	137
34	402	120
36	384	128
38	367	114
40	353	114
42	336	99
44	323	109
46	312	102
48	300	95
50	288	97
52	278	93
54	271	92
56	269	86
58	267	87
60	265	86
61	263	89

Location 2 - 5 m from facade 4.5 m height.


Location 2 - 5 m from facade 4.5 m height.

Min. / °C	Plate TC.3
0	23
2	23
4	32
6	63
8	103
10	133
12	158
14	177
15	188
16	198
18	221
20	243
22	256
24	261
26	255
28	245
30	233
32	223
34	215
36	208
38	201
40	191
42	182
44	176
46	170
48	163
50	157
52	152
54	151
56	151
58	148
60	146
61	144

Location 1 - TC on PlateTC

Location 1 - TC on PlateTC


Min. / °C	TC on PlateTC.1
0	23
2	24
4	39
6	49
8	64
10	62
12	73
14	80
15	81
16	83
18	93
20	96
22	99
24	100
26	100
28	93
30	91
32	80
34	76
36	73
38	78
40	69
42	68
44	65
46	59
48	59
50	60
52	60
54	60
56	62
58	58
60	59
61	55

Location 1 - TC on Flux*Flux.TC.2 located 3 m from fire chamber*

Location 1 - TC on Flux

Flux.TC.2 located 3 m from fire chamber

Min. / °C	Flux.TC.1
0	23
2	23
4	24
6	26
8	29
10	40
12	53
14	61
15	48
16	44
18	46
20	47
22	51
24	54
26	55
28	57
30	59
32	60
34	62
36	64
38	61
40	62
42	61
44	63
46	64
48	63
50	62
52	60
54	59
56	61
58	61
60	60
61	59

Location 2 - TC


Location 2 - TC

TC.1 Location 1

TC.2 Location 2


Min. / °C	Loc 2.1	Loc 2.2
0	24	23
2	24	23
4	29	37
6	34	81
8	41	125
10	48	161
12	50	188
14	55	210
15	57	218
16	60	227
18	60	248
20	65	266
22	65	283
24	67	285
26	62	280
28	59	269
30	57	254
32	55	243
34	53	229
36	54	216
38	51	207
40	50	195
42	46	185
44	46	177
46	48	171
48	46	166
50	43	159
52	43	151
54	41	148
56	44	147
58	42	145
60	42	144
61	41	144

Temperature rise measured 50mm from the facade




Temperature rise measured 50mm from the facade

Min. / °C	I.1.1	I.1.2	I.1.3	I.1.4	I.1.5	I.1.6	I.1.7	I.1.8	I.1.9
0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0
4	29	148	79	70	36	8	15	14	21
6	34	168	80	62	36	19	29	31	43
8	52	185	93	79	59	27	43	44	64
10	57	210	106	89	53	34	54	54	87
12	72	222	106	94	66	37	61	60	93
14	80	232	101	90	57	43	72	65	110
15	72	231	107	97	72	47	76	70	109
16	80	236	112	106	72	48	78	74	113
18	113	282	142	131	78	56	103	87	138
20	138	320	137	124	86	105	104	110	141
22	115	251	117	111	69	132	98	351	136
24	119	255	118	111	64	130	95	166	136
26	129	243	116	102	67	135	85	180	115
28	114	271	119	103	63	57	77	65	96
30	124	251	119	104	69	51	74	45	93
32	112	204	119	99	60	67	69	36	108
34	106	178	108	94	58	79	78	36	90
36	100	170	114	99	62	84	73	41	90
38	100	165	112	98	60	78	73	51	81
40	142	143	104	90	54	76	75	57	72
42	153	134	99	85	55	84	71	84	63
44	165	131	95	87	49	103	68	68	54
46	185	137	88	83	49	105	71	86	48
48	146	139	70	65	46	144	68	81	42
50	149	142	64	57	39	420	64	85	43
52	170	149	62	57	38	742	58	121	40
54	164	139	58	55	38	774	50	187	39
56	173	133	61	56	44	889	57	204	43
58	117	112	59	55	40	392	55	326	38
60	101	110	57	51	39	262	58	490	38
61	92	103	56	52	43	245	70	479	39

Temperature rise measured in ventilation layer

Temperature rise measured in ventilation layer


Min. / °C	I.2.1	I.2.2	I.2.3	I.2.4	I.2.5
0	0	0	0	0	0
2	0	0	0	0	0
4	0	0	0	0	0
6	0	0	0	0	0
8	0	0	0	0	0
10	0	0	0	0	0
12	0	0	0	0	0
14	0	0	0	0	0
15	0	0	0	0	0
16	0	0	0	0	0
18	0	0	0	0	0
20	0	0	0	0	0
22	0	0	0	0	0
24	0	0	0	0	0
26	0	0	1	0	0
28	0	0	1	0	0
30	0	0	2	0	0
32	0	0	2	0	0
34	0	1	3	1	0
36	0	1	4	1	0
38	1	1	5	3	0
40	1	1	6	6	0
42	1	2	7	11	0
44	1	2	7	16	1
46	2	3	8	22	1
48	2	3	9	27	1
50	2	3	10	32	1
52	2	4	10	36	2
54	2	4	11	40	3
56	2	4	11	43	6
58	3	5	12	47	11
60	3	5	12	51	17
61	3	5	12	53	20

Temperature rise measured in middle of insulation

Temperature rise measured in middle of insulation

Min. / °C	I.3.1	I.3.2	I.3.3	I.3.4	I.3.5
0	0	0	0	0	0
2	0	0	0	0	0
4	0	1	6	27	0
6	0	2	10	33	0
8	0	5	16	36	0
10	0	6	19	32	0
12	0	9	23	35	0
14	0	11	27	39	0
15	0	12	29	39	0
16	0	13	32	39	1
18	1	16	41	41	1
20	1	19	46	46	1
22	1	23	45	42	1
24	2	25	47	37	2
26	2	26	49	40	2
28	3	26	48	63	3
30	4	26	50	126	4
32	4	27	50	369	4
34	5	25	48	371	5
36	6	25	49	332	6
38	6	25	49	365	7
40	7	23	47	402	8
42	8	22	46	449	9
44	8	22	48	497	11
46	9	22	44	534	17
48	9	23	43	553	53
50	10	22	38	581	69
52	10	22	39	625	74
54	11	21	37	748	99
56	11	21	33	818	155
58	12	21	33	897	208
60	12	20	32	957	263
61	13	21	31	932	292

**Temperature rise measured according to the standard - 50 mm from facade.
Minimum of 30 sec**




Temperature rise measured according to the standard - 50 mm from facade.
Minimum of 30 sec

Min. / °C	I.1.1	I.1.2	I.1.3	I.1.4	I.1.5	I.1.6	I.1.7	I.1.8	I.1.9	I.1.Max
0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0
4	29	127	66	51	22	6	8	10	14	127
6	28	159	69	58	29	17	23	30	41	159
8	43	178	88	76	48	27	41	42	59	178
10	49	186	99	83	53	33	53	51	83	186
12	61	208	96	86	56	36	57	58	87	208
14	78	226	94	85	54	42	64	64	108	226
15	71	209	97	85	56	45	69	67	103	209
16	76	227	109	99	62	45	75	73	102	227
18	100	272	140	131	76	56	93	86	129	272
20	125	290	132	121	79	78	97	101	141	290
22	113	251	114	108	67	125	98	330	135	330
24	115	239	111	104	63	114	94	162	135	239
26	118	240	112	98	67	132	85	162	114	240
28	114	252	109	101	62	56	74	63	96	252
30	112	243	111	93	59	50	70	44	87	243
32	108	198	103	88	60	64	69	36	104	198
34	105	178	108	93	58	78	70	35	90	178
36	96	167	114	99	58	76	71	38	88	167
38	100	155	105	93	56	78	69	46	78	155
40	126	143	101	90	51	76	73	52	69	143
42	151	133	94	84	49	83	67	71	58	151
44	157	127	94	85	49	94	67	64	53	157
46	163	128	83	76	46	95	65	82	46	163
48	146	133	69	62	44	116	65	74	42	146
50	140	141	62	56	39	352	61	85	39	352
52	148	142	60	56	36	661	56	109	39	661
54	164	133	54	51	36	744	50	167	38	744
56	166	126	59	53	39	819	54	192	39	819
58	111	111	57	53	38	372	48	263	38	372
60	97	102	54	50	39	262	56	466	36	466
61	89	98	52	48	37	244	55	445	37	445

Failure [min]	-	-	-	-	-	51.33	-	59.67	-	51.33
Failure°C	500	500	500	500	500	500	500	500	500	500


**Temperature rise measured according to the standard - ventilation layer.
Minimum of 30 sec**



Temperature rise measured according to the standard - ventilation layer.
Minimum of 30 sec

Min. / °C	I.2.1	I.2.2	I.2.3	I.2.4	I.2.5	I.2.Max
0	0	0	0	0	0	0
2	0	0	0	0	0	0
4	0	0	0	0	0	0
6	0	0	0	0	0	0
8	0	0	0	0	0	0
10	0	0	0	0	0	0
12	0	0	0	0	0	0
14	0	0	0	0	0	0
15	0	0	0	0	0	0
16	0	0	0	0	0	0
18	0	0	0	0	0	0
20	0	0	0	0	0	0
22	0	0	0	0	0	0
24	0	0	0	0	0	0
26	0	0	1	0	0	1
28	0	0	1	0	0	1
30	0	0	2	0	0	2
32	0	0	2	0	0	2
34	0	1	3	1	0	3
36	0	1	4	1	0	4
38	1	1	5	3	0	5
40	1	1	6	5	0	6
42	1	2	6	10	0	10
44	1	2	7	15	1	15
46	1	2	8	21	1	21
48	2	3	9	26	1	26
50	2	3	10	31	1	31
52	2	3	10	35	2	35
54	2	4	11	39	3	39
56	2	4	11	43	5	43
58	3	4	12	46	10	46
60	3	5	12	50	16	50
61	3	5	12	52	19	52

Failure [min]	-	-	-	-	-	-
Failure°C	500	500	500	500	500	500


Temperature rise measured according to the standard - in the middle of the insulation. Minimum of 30 sec

Temperature rise measured according to the standard - in the middle of the insulation. Minimum of 30 sec

Min. / °C	I.3.1	I.3.2	I.3.3	I.3.4	I.3.5	I.3.Max
0	0	0	0	0	0	0
2	0	0	0	0	0	0
4	0	1	5	22	0	22
6	0	2	9	31	0	31
8	0	4	14	34	0	34
10	0	6	18	32	0	32
12	0	8	21	34	0	34
14	0	11	25	37	0	37
15	0	12	28	39	0	39
16	0	13	31	38	0	38
18	0	15	40	40	1	40
20	1	19	43	42	1	43
22	1	22	45	42	1	45
24	1	24	46	37	2	46
26	2	25	48	38	2	48
28	3	25	48	55	3	55
30	3	26	50	114	4	114
32	4	26	49	273	4	273
34	5	25	48	367	5	367
36	5	25	49	332	6	332
38	6	24	49	355	6	355
40	7	23	47	392	7	392
42	7	22	46	431	9	431
44	8	22	47	483	10	483
46	8	22	44	525	15	525
48	9	22	42	550	43	550
50	10	22	38	571	66	571
52	10	22	39	620	73	620
54	11	21	37	708	91	708
56	11	21	33	818	145	818
58	12	21	33	876	196	876
60	12	20	31	956	251	956
61	12	21	31	921	279	921

Failure [min]	-	-	-	44.42	-	44.42
Failure°C	500	500	500	500	500	500


Vertical measurements on main facade



Vertical measurements on main facade

Min. / °C	F.1.1	F.1.2	F.1.3	F.1.4	F.1.5	F.1.6	F.1.7
0	23	23	23	23	23	23	23
2	23	23	23	23	23	23	23
4	166	133	153	112	223	222	224
6	181	129	169	127	270	246	262
8	193	153	182	144	390	446	557
10	222	164	205	167	379	399	466
12	224	158	211	185	567	472	534
14	229	163	214	180	515	468	502
15	236	167	203	181	549	486	531
16	240	185	219	205	610	472	524
18	282	214	269	251	764	541	555
20	283	198	266	254	789	658	687
22	238	177	225	215	752	552	545
24	229	174	222	225	736	571	569
26	231	175	221	204	180	612	709
28	257	181	238	206	161	702	635
30	269	166	246	229	128	770	492
32	218	170	202	178	141	669	342
34	198	168	196	179	125	530	293
36	214	178	203	200	98	430	270
38	189	165	193	196	41	53	237
40	160	153	168	175	41	58	203
42	153	141	165	173	42	59	167
44	152	139	162	162	44	49	163
46	145	124	147	148	59	61	174
48	145	108	145	135	71	59	159
50	152	106	154	127	71	57	97
52	154	112	158	137	75	70	132
54	132	100	132	118	277	83	249
56	135	97	128	115	417	113	169
58	120	91	110	96	400	101	106
60	121	89	105	92	111	126	167
61	118	86	107	94	92	145	286


Vertical measurements on main facade



Vertical measurements on main facade


Min. / °C	F.1.8	F.1.9	F.1.10	F.1.11	F.1.12	F.1.13
0	23	23	23	23	23	23
2	23	23	23	23	23	23
4	236	235	186	207	135	232
6	275	283	163	283	219	758
8	481	532	397	544	789	728
10	464	512	386	560	725	736
12	500	539	358	553	703	770
14	500	541	364	557	730	809
15	543	607	393	586	753	826
16	505	531	374	560	785	849
18	523	542	364	576	760	834
20	678	747	500	684	806	831
22	545	612	349	619	774	838
24	558	608	399	586	745	836
26	619	603	336	520	578	795
28	620	621	489	743	735	786
30	587	573	470	309	638	616
32	283	367	457	309	528	242
34	271	344	349	666	488	167
36	230	265	438	300	568	152
38	224	251	483	273	557	140
40	181	201	380	309	551	131
42	146	177	349	308	515	126
44	135	168	348	334	474	120
46	168	181	295	267	403	120
48	157	174	134	122	341	119
50	146	209	60	59	266	100
52	203	269	61	63	219	88
54	485	478	60	60	195	89
56	332	293	69	66	159	99
58	187	104	76	70	134	117
60	232	118	79	71	132	131
61	255	123	86	76	134	145

Vertical measurements on the wing



Vertical measurements on the wing


Min. / °C	F.2.4	F.2.5	F.2.6	F.2.7	F.2.8
0	23	23	23	23	23
2	23	23	23	23	23
4	100	97	87	66	95
6	99	93	76	49	93
8	117	108	92	62	104
10	118	114	101	68	139
12	120	121	107	78	134
14	114	111	100	72	135
15	132	118	108	74	140
16	121	131	117	89	154
18	152	146	134	100	212
20	140	139	131	99	206
22	128	125	113	90	187
24	126	120	113	90	190
26	135	124	107	87	184
28	130	126	105	89	179
30	134	130	115	97	182
32	129	125	110	93	198
34	126	117	107	91	199
36	122	114	105	92	199
38	118	114	107	91	194
40	124	117	99	84	185
42	111	107	98	84	184
44	107	103	93	83	176
46	101	98	96	81	164
48	87	85	82	72	155
50	85	80	75	71	144
52	80	78	76	67	122
54	78	76	73	65	117
56	86	82	77	72	126
58	82	80	75	65	116
60	83	79	72	65	124
61	79	76	73	68	123

Vertical measurements on the wing

Vertical measurements on the wing

Min. / °C	F.2.9	F.2.10	F.2.11	F.2.12	F.2.13	F.2.14
0	23	23	23	23	23	23
2	23	23	23	23	23	23
4	61	50	45	45	46	57
6	65	61	58	59	69	87
8	84	84	80	79	99	107
10	96	98	91	93	108	121
12	109	107	102	106	134	135
14	117	120	116	125	148	155
15	119	123	117	125	163	166
16	114	120	122	131	159	169
18	160	164	163	174	177	179
20	154	164	168	179	173	190
22	142	149	151	159	163	190
24	135	147	148	153	157	191
26	139	140	132	139	136	185
28	129	128	129	131	123	188
30	143	139	129	127	124	187
32	157	155	150	154	123	193
34	171	167	165	154	111	171
36	162	160	155	149	115	166
38	161	157	161	153	124	167
40	149	148	148	145	115	148
42	152	154	155	147	122	140
44	140	141	133	130	95	125
46	137	134	130	125	114	122
48	138	136	128	114	95	120
50	129	132	128	120	103	112
52	108	111	105	101	90	111
54	104	108	103	111	90	112
56	113	113	110	114	107	111
58	106	105	97	97	84	103
60	115	114	111	113	96	106
61	117	116	110	106	91	104


Horizontal measurements



Horizontal measurements

Min. / °C	F.3.1	F.3.2	F.3.3	F.3.4	F.3.5	F.3.6	F.3.7
0	23	23	23	23	23	23	23
2	23	23	23	23	23	23	23
4	56	156	218	134	89	76	40
6	54	191	276	121	90	64	57
8	65	182	269	176	111	85	69
10	82	184	287	248	141	94	77
12	83	224	372	278	137	108	83
14	93	362	495	272	153	106	88
15	96	247	415	307	152	110	95
16	93	241	438	436	159	122	100
18	113	322	605	442	506	150	122
20	199	719	759	505	409	155	576
22	228	443	675	310	239	136	307
24	173	550	733	318	243	137	184
26	126	554	624	290	248	150	148
28	96	699	935	385	250	125	96
30	88	625	877	522	281	148	77
32	96	538	968	803	260	127	67
34	96	418	543	758	258	141	69
36	92	321	421	745	348	130	69
38	86	49	52	70	95	129	75
40	85	50	54	98	106	125	81
42	87	48	53	87	113	123	96
44	94	47	49	100	114	117	86
46	98	53	57	109	121	119	96
48	169	68	67	90	122	108	100
50	582	74	68	91	118	108	108
52	816	469	109	96	124	93	157
54	841	366	171	296	169	90	223
56	831	315	298	273	187	98	396
58	677	391	242	229	164	94	489
60	302	439	290	361	153	104	619
61	268	447	323	256	174	107	173

Horizontal measurements



Horizontal measurements

Min. / °C	F.3.8	F.3.9	F.3.10	F.3.11	F.3.12	F.3.13
0	23	23	23	23	23	24
2	23	23	23	23	24	24
4	67	147	171	56	40	108
6	143	330	122	78	56	588
8	169	537	194	126	71	519
10	330	505	359	134	87	504
12	327	514	341	152	94	491
14	321	528	342	169	99	675
15	368	559	337	184	103	732
16	372	567	358	266	108	852
18	374	624	335	398	118	858
20	353	628	383	380	133	848
22	349	590	306	339	129	829
24	339	598	322	303	130	791
26	305	586	275	264	116	750
28	272	382	631	245	104	559
30	286	269	516	222	96	437
32	372	357	577	240	104	188
34	434	350	285	465	104	118
36	346	494	417	197	105	113
38	364	384	378	189	102	102
40	261	223	304	185	101	108
42	255	219	285	166	102	100
44	243	249	225	158	88	88
46	233	764	280	150	98	94
48	180	878	99	63	83	90
50	134	837	53	43	91	70
52	143	900	53	43	79	66
54	145	895	51	47	80	70
56	135	65	54	58	89	72
58	149	68	58	60	73	81
60	154	74	62	70	89	128
61	164	74	64	74	91	160



Plate thermocouple on facade


Plate thermocouple on facade

Min. / °C	PlateTC.1	PlateTC.2
0	24	23
2	24	23
4	58	26
6	103	35
8	133	45
10	151	53
12	166	60
14	172	66
15	175	69
16	182	72
18	204	79
20	212	87
22	213	90
24	203	91
26	193	87
28	189	80
30	188	71
32	186	67
34	182	66
36	177	61
38	171	64
40	160	57
42	151	56
44	145	56
46	137	54
48	127	52
50	120	52
52	114	52
54	108	52
56	104	53
58	100	55
60	97	57
61	95	58

Heat flux on window

Heat flux on window


Min. / kW/m ²	Heat flux on window.1
0	0
2	0
4	3
6	9
8	9
10	10
12	16
14	14
15	17
16	13
18	22
20	30
22	28
24	25
26	18
28	10
30	11
32	10
34	8
36	7
38	6
40	6
42	4
44	3
46	3
48	2
50	2
52	4
54	4
56	6
58	5
60	4
61	5

TC on window heat Flux*Flux.TC. on window*

TC on window heat Flux

Flux.TC. on window

Min. / °C	TC on window heat flux.1
0	22
2	22
4	25
6	25
8	28
10	29
12	30
14	30
15	31
16	32
18	33
20	35
22	37
24	37
26	35
28	31
30	30
32	30
34	29
36	29
38	29
40	28
42	28
44	28
46	29
48	31
50	31
52	32
54	32
56	33
58	34
60	35
61	35

Temperature rise measured behind the windbreaker board

Temperature rise measured behind the windbreaker board

Min. / °C	IV 1.1	IV 1.2	IV 1.3	IV 1.4	IV 1.5	IV 1.Max
0	0	0	0	0	0	0
2	0	0	0	0	0	0
4	1	1	0	0	0	1
6	6	6	2	1	1	6
8	16	16	4	3	2	16
10	38	48	7	11	4	48
12	77	77	14	27	8	77
14	96	103	21	53	12	103
15	127	136	24	66	13	136
16	175	186	26	71	15	186
18	310	329	31	71	18	329
20	414	422	35	69	23	422
22	484	483	37	76	46	484
24	600	563	39	100	52	600
26	659	611	41	144	55	659
28	665	630	49	238	55	665
30	645	638	81	371	75	645
32	617	640	116	462	77	640
34	581	631	213	515	183	631
36	533	616	349	562	359	616
38	486	608	450	575	433	608
40	446	595	510	549	459	595
42	411	576	569	519	470	576
44	379	563	571	484	455	571
46	349	543	531	435	428	543
48	322	502	476	398	396	502
50	299	459	427	367	363	459
52	279	420	386	342	338	420
54	264	385	351	319	326	385
56	251	354	319	304	316	354
58	239	325	291	292	296	325
60	229	300	266	282	271	300
61	224	289	255	279	260	289

Failure [min]	22.33	22.42	39.75	33.50	-	22.33
Failure°C	500	500	500	500	500	500




Photo No. 1 Prefabricated cassettes being mounted.



Photo No. 2 Fixing of prefabricated cassettes.



Photo No. 3 Insulation mounted between the prefabricated cassettes.



Photo No. 4 Connection between prefabricated cassettes.



Photo No. 5 Steel flashing around window mounted.



Photo No. 6 Vertical formwork mounted with room for flame deflector.




Photo No. 7 Horizontal formwork and flame deflector mounted.




Photo No. 8 Vertical cladding is mounted.




Photo No. 9 Vertical cladding mounting done. Insulation inside flame deflectors mounted.



Photo No. 10 Test specimen before test start.




Photo No. 11 Test specimen 10 seconds into the test.



Photo No. 12 Test specimen 1:30 minutes into the test.



Photo No. 13 Test specimen 3:30 minutes into the test.



Photo No. 14 Test specimen 6 minutes into the test.



Photo No. 15 Test specimen 8 minutes into the test.



Photo No. 16 Test specimen 13 minutes into the test.




Photo No. 17 Test specimen 19 minutes into the test.



Photo No. 18 Test specimen 25 minutes into the test.




Photo No. 19 Test specimen 34 minutes into the test.



Photo No. 20 Test specimen 36 minutes into the test.



Photo No. 21 Test specimen 50 minutes into the test.



Photo No. 22 Test specimen 56 minutes into the test.



Photo No. 23 Test specimen 60 minutes into the test.



Photo No. 24 Test specimen after the test.



Photo No. 25 Test specimen after the test. Detailed photo below the first flame deflector.





Photo No. 26 Test specimen after the test. Detailed photo of edge of burn specimen.



Photo No. 27 Test specimen after the test. Detailed photo below the second flame deflector.



Photo No. 28 Test specimen after the test. Detailed photo of the top prefabricated cassette.



BFUH-9 Facadetest ved DBI - Test 1

Gældende

Facaderamme


BYGGERE:
Fælledby
-

DATO: 2024-08-01 REV. NR/DATO: A 2024-08-14

ANSV: CMA MÅL: 1:30 ANTAL: -

TEGN.NR: 1

A) Element ændret til version som BFUH 7



Materialer:

Vindspærre:

9 mm Swisspearl Windstopper Extreme 1200x3000

Knauf W-tape til lodrette og vandrette samlinger

13 mm T-profil – leveres af BM Byggeindustri A/S

Ringede galvaniserede pistolsøm 2,5 x 50

195mm Stenuld kl 37

12mm OSB3 1220x2420 på bagside for at holde på isolering. Samme befæstigelser som vindspærre.

Generelt:

-

Opbygning:

22mm Frøslev klinkeprofil – Termowood (lodret)

22x45mm Afstandslister (brandimprægnerede) pr. 600mm (krydsforskælt)

9mm Swisspearl Windstopper Extreme

45x195mm stoplekonstruktion pr. 600mm


195mm Stenuld (isolering kl 37)

195mm Stenuld (isolering kl 37) (over vinduer og i lukkestykker)


Revisionstekst:

A) Element ændret til version som BFUH 7


SNIT E-E



SNIT D-D



SNIT C-C



Mads Mads

BFUH-9 Facadetest ved DBI - Test 1

Vindspærre

BYGGERE:

Fælledby

-

DATO: 2024-08-01

REV. NR/DATO:

Gældende

A 2024-08-14

ANSV: CMA


MÅL: 1:30

ANTAL: -

TEGN.NR:

2

Lodrette afstandslistre



Materialer:

22x45mm afstandslistre i gran ubehandlet LBM:
Ringede galvaniserede pistolsøm 2,8 x 75
Flammedfører leveres af Facadeplan

Vinduesindækninger leveres af BM Byggeindustri og monteres inden afstandslistre

Generelt:

- Opbygning:

22mm Frøslev klinkeprofil - Termowood (lodret)
22x45mm Afstandslistre (brandimpregnere) pr. 600mm
(krydsforskælt)
9mm Swisspearl Windstopper Extreme
45x195mm stoplekonstruktion pr. 600mm
195mm Stenuld (isolering kl 37)
195mm Stenuld (isolering kl 37) (over vinduer og i lukkestykker)

Revisionstekst:


A) Element ændret til version som BFUH 7

B)

SNIT E-E

SNIT D-D

SNIT C-C



BFUH-9 Facadetest ved DBI - Test 1

Gældende

L Afstandslistre

BYGHERRE:
Fælledby
-

DATO: 2024-08-01

REV. NR/DATO:

A 2024-08-14



ANSV: CMA

MÅL: 1:30

ANTAL: -

TEGN.NR:

3



Materialer:

22x45mm + 22x95 afstandsliste i gran ubehandlet LBM:

Ringede galvaniserede pistolsøm 3,1 x 90

Generelt:

-
Opbygning:

22mm Frøslev klinkprofil - Termowood (lodret)

22x45mm Afstandsliste (brandimpregnere) pr. 600mm (krydsforskallet)

9mm Swisspearl Windstopper Extreme

45x195mm stoplekonstruktion pr. 600mm


195mm Stenuld (isolering kl 37)

195mm Stenuld (isolering kl 37) (over vinduer og i lukkestykker)

Revisionstekst:

A) Element ændret til version som BFUH 7

B)



BFUH-9 Facadetest ved DBI - Test 1

V Afstandsliste

BYGHERRER:
Fælledby
-

DATO: 2024-08-01

REV. NR/DATO:

Gældende

ANSV: CMA



MÅL: 1:30

ANTAL: -

TEGN.NR:

4

Facade



Materialer:

22mm Frøslev klinkeprofil – Termowood (lodret) LBM:

Rundhovedet rustfri A4 pistolsøm 2,5x50

Generelt:

-

Opbygning:

22mm Frøslev klinkeprofil – Termowood (lodret)

22x45mm Afstandslister (brandimpregnerede) pr. 600mm (krydsforskallet)

9mm Swisspearl Windstopper Extreme

45x195mm stoplekonstruktion pr. 600mm


195mm Stenuld (isolering kl 37)

195mm Stenuld (isolering kl 37) (over vinduer og i lukkestykker)

SNIT E-E

SNIT D-D

SNIT C-C



BFUH-9 Facadetest ved DBI - Test 1

Facadebeklædning

BYGHERRE:

Fælledby

-

DATO: 2024-08-01

REV. NR/DATO:

Gældende

A 2024-08-14

ANSV: CMA

MÅL: 1:30


ANTAL: -

TEGN.NR:

5

Revisionstekst:

A) Element ændret til version som BFUH 7



BFUH-9 Facadetest ved DBI - Test 1

Detaljer

BYGHERRE:
Fælledby
-




DATO: 2024-08-01 REV. NR/DATO: A 2024-08-14

ANSV: CMA MÅL: 1:5 ANTAL: -

TEGN.NR: DE01-03

Mads Mads

DBI
PGC10039A



SCALE 1 : 7

DBI
PGC10039A


Mads Mads
OV: R1
UV: Spor 12
BT: 0,5 mm

DRAWN	NAME	DATE	Folder name: X:\Facadeplan\BFUH-8\ Customer:
	casper	14-08-2024	
			TITLE: 2 mm plade
			MATERIAL: DX51D Z275 (Varm-Galv)
			DWG NO. GKB-122142-10
			REVISION
			SCALE:1:5
			A3 SHEET 1 OF 1

Hvor intet andet er angivet, er tolerancer
i henhold til DS/ISO 2768-1(m)
Alle mål er i millimeter, medmindre
andet er angivet.
Tegningen må ikke skaleres.






WEIGHT: 20383.22



Mads Mads
OV: R1
UV: Spor 12
BT: 0,5 mm

DRAWN	NAME	DATE	Folder name: X:\Facadeplan\BFUH-8\ Customer:
	casper	14-08-2024	
			TITLE: 2 mm plade
			MATERIAL: DX51D Z275 (Varm-Galv)
			DWG NO. GKB-122142-20
			REVISION
		Hvor intet andet er angivet, er tolerancer i henhold til DS/ISO 2768-1(m) Alle mål er i millimeter, medmindre andet er angivet. Tegningen må ikke skaleres.	SCALE:1:5
			A3 SHEET 1 OF 1
		WEIGHT: 20383.22	





DRAWN	NAME	DATE	Folder name:
	casper	15-08-2024	X:\Facadeplan\BFUH-8\
			Customer:
			TITLE:
			2 mm plade
		MATERIAL:	DWG NO.
		DX51D Z275 (Varm-Galv)	GKB-122142-30
		WEIGHT: 20383.22	SCALE: 1:3
			REVISION
			A3 SHEET 1 OF 1

Hvor intet andet er angivet, er tolerancer
i henhold til DS/ISO 2768-1(m)
Alle mål er i millimeter, medmindre
andet er angivet.
Tegningen må ikke skaleres.



Mads Mads
OV: R1
UV: Spor 12
BT: 0,5 mm



DBI
PGC10039A

Mads Mads

OV: R1
UV: Spor 12
BT: 0,5 mm


DRAWN	casper	DATE	14-08-2024	Folder name: X:\Facadeplan\BFUH-8\
				Customer:
				TITLE: 2 mm plade
				MATERIAL: DX51D Z275 (Varm-Galv)
				DWG NO. GKB-122142-40
				REVISION
				SCALE:1:5
				A3 SHEET 1 OF 1




Hvor intet andet er angivet, er tolerancer
i henhold til DS/ISO 2768-1(m)
Alle mål er i millimeter, medmindre
andet er angivet.
Tegningen må ikke skaleres.



MATERIAL:
DX51D Z275 (Varm-Galv)

WEIGHT: 4105.14





DBI
PGC10039A




Mads Mads

OV: R1
UV: Spor 6
BT: 0,2 mm

DRAWN	casper	DATE	13-08-2024	Folder name: X:\Facadeplan\BFUH-8\ Customer:
				TITLE: 1 mm plade
				MATERIAL: DX51D Z275 (Varm-Galv)
				DWG NO.
				REVISION
				Indd. 1290
			WEIGHT: 2.04	SCALE: 1:2
				A3 SHEET 1 OF 1

Hvor intet andet er angivet, er tolerancer
i henhold til DS/ISO 2768-1(m)
Alle mål er i millimeter, medmindre
andet er angivet.
Tegningen må ikke skaleres.





DBI
PGC10039A


Mads Mads

OV: R1
UV: Spor 6
BT: 0,2 mm


DRAWN	casper	DATE	13-08-2024	NAME	DATE	Folder name: X:\Facadeplan\BFUH-8\
						Customer:
						TITLE:
						1 mm plade
				MATERIAL:	DWG NO.	REVISION
				DX51D Z275 (Varm-Galv)	Indd. 2090	
				WEIGHT: 3,35	SCALE: 1:2	A3 SHEET 1 OF 1

Hvor intet andet er angivet, er tolerancer
i henhold til DS/ISO 2768-1(m)
Alle mål er i millimeter, medmindre
andet er angivet.
Tegningen må ikke skaleres.






DETAIL B
SCALE 2 : 3



SECTION A-A
SCALE 1 : 3



DRAWN	NAME	DATE	Folder name: X:\Facadeplan\BFUH-8\
	casper	14-08-2024	Customer:
			TITLE:
			MATERIAL: Material <not specified>
			DWG NO. samlet
			REVISION
			WEIGHT: 63186.37
			SCALE: 1:20
			A3 SHEET 1 OF 1

Hvor intet andet er angivet, er tolerancer
i henhold til DS/ISO 2768-1(m)
Alle mål er i millimeter, medmindre
andet er angivet.
Tegningen må ikke skaleres.



MATERIAL: Material <not specified>
WEIGHT: 63186.37

SCALE: 1:20

A3 SHEET 1 OF 1